

Pawtucket Housing Authority
214 Roosevelt Ave. Pawtucket RI,02860
Addendum #2

4/16/2025
Kennedy Manor
175 Broad St
Pawtucket, RI 02860

Bidders are hereby informed that specifications for the above mentioned project are modified, corrected, and/or supplemented as follows and Addendum #2 becomes part of the bid documents:

RFI

1. Will there be fiber between the switches?
 - a. Yes – please include fiber between the switches in your scope
2. Outside seems to be coax, should we switch to cat-6?
 - a. Yes – please price for cat-6 connections for all spec'ed exterior cameras

Capital Projects Coordinator
Alissa Stipa 401-265-0773
astipa@pawthousing.org